

CERTIFICATE

N.9Y56474

Expiry date:09/02/2022



Holder of Certificate:

Classification: IAQ -(Indoor air quality)

particle and microbiological contamination educational areas

MICROBIOLOGICAL/PHYSICAL TESTS

Parameters:	CBT(36°C,22°C)	Staphilococcus spp
	CMT(36°C,22°C)	Pseudomonas spp
	Legionellaceae	Enterobacteriaceae
	Bacilli GRAM-	Aspergillus spp
	Aerodisperse particulate	

Tested acc.to:	ISO14644-1:2015	UNI EN 13098:2002
	ISO21501-4	ISPESL 2009

Limite Value:	≤ISO CLASS 5	≤3520/m ³
	UFC/m ³	<35UFC/m ³
	Absence of airborne pathogens	

Equipment: Aerosol Particle Counter **Lasair III**
 calibration term:09/08/2022
 Microbial Air Sampler **MAS100NT**
 calibration term:09/12/2022

Final evaluation:

In accordance to the tests performed, the educational areas of Complesso Scolastico Cardinal Ragonesi meets the compliance requirements established by the quality assurance program and by national and international guidelines on the prevention and control of the airborne infections..The concentration of the particles calculated is in accordance with the UNI EN ISO standard and the airborne microbial loads in line with the expected reference values.

Testing Specialist:
Dr Fabrizio Conti

Rome, 09/02/2021

